


Scenariu de accident cu incendiu la Rezervorul de hexan T8
IAFPE_T8_PoolFire



- Mortalitate ridicata 12.5 kW/mp
- Prag de mortalitate 7 kW/mp
- Vătămări ireversibile 5 kW/mp
- Vătămări reversibile 3 kW/mp

ID_Eveniment	IAFPE_T8_PoolFire
Instalatie	Rezervorul de hexan T8
Tip_Eveniment	PoolFire
Substanta	Hexan
Localitate	Ploiesti
Frecventa	1E-06
	an ⁻¹
Zona_I	37
	m
Zona_II	54
	m
Zona_III	70
	m
Zona_IV	107
	m

0 70 140 280 Meters

Scale: 1/3.000

GEPAR SRL
Woodworking
supply store

Google